

SMOKE DETECTOR WITH BUILT-IN WIRELESS TRANSMITTER

INSTALLATION INSTRUCTIONS


GENERAL INFORMATION

The 5706 Photoelectric Smoke Detector/Transmitter is intended for use with wireless alarm systems that support 5700 series devices, and contains a built-in transmitter which can send alarm, supervisory and battery condition messages to the system's receiver/control unit. Refer to the wireless system's instructions for the maximum number of detectors that can be supported.

Alarms: The smoke detector is powered by one or two 9 volt batteries (two batteries increase battery life) and will sound its built-in horn (LED indicator flashes rapidly) when smoke reaches the detector. A message will be sent to the wireless control and the smoke detector's ID number will be displayed at the console. The alarm message will be transmitted every 12 seconds, until the smoke condition has cleared and the detector has reset. About 1 second after the horn has stopped, the console will emit a pair of tones and the ID number will clear from the display. During normal and low battery conditions, the LED indicator will flash about once every 12 seconds.

Low Battery: The detector indicates low battery conditions by two, independent means. First, the detector will emit a "chirp" (beeps about once every 50 seconds) when a drop in voltage is sensed. The battery should be replaced within 30 days following the low battery beeps. In addition, when the detector's battery voltage reaches a predetermined level, the detector will transmit a low battery message to the wireless control, with the detector's ID number displayed at the console.

False Alarm Protection: In order to reduce the possibility of false alarms due to cigarette smoke, dust, steam, insects, etc., the detector will not transmit an alarm until its horn has sounded continuously for about 6 seconds. A delay also occurs when testing the detector. Therefore, the test button must be held down for about 15 seconds before the horn will sound. The first alarm signal will be transmitted within 20 seconds after the horn sounds.




SETTING THE DETECTOR'S DIP SWITCH

The detector's DIP switches must be set for the assigned House ID and Transmitter ID numbers before the unit will operate with the wireless system. Set the switches as shown.

House ID Switch Setting					
HOUSE ID	DIP SWITCH SETTINGS				
	1	2	3	4	5
1	UP	UP	UP	UP	dn
2	UP	UP	UP	dn	UP
3	UP	UP	UP	dn	dn
4	UP	UP	dn	UP	UP
5	UP	UP	dn	UP	dn
6	UP	UP	dn	dn	UP
7	UP	UP	dn	dn	dn
8	UP	dn	UP	UP	UP
9	UP	dn	UP	UP	dn
10	UP	dn	UP	dn	UP
11	UP	dn	UP	dn	dn
12	UP	dn	dn	UP	UP
13	UP	dn	dn	UP	dn
14	UP	dn	dn	dn	UP
15	UP	dn	dn	dn	dn
BIT VALUE:	16	8	4	2	1

HOUSE ID					
HOUSE ID	DIP SWITCH SETTINGS				
	1	2	3	4	5
16	dn	UP	UP	UP	UP
17	dn	UP	UP	UP	dn
18	dn	UP	UP	dn	UP
19	dn	UP	UP	dn	dn
20	dn	UP	dn	UP	UP
21	dn	UP	dn	UP	dn
22	dn	UP	dn	dn	UP
23	dn	UP	dn	dn	dn
24	dn	dn	UP	UP	UP
25	dn	dn	UP	UP	dn
26	dn	dn	UP	dn	UP
27	dn	dn	UP	dn	dn
28	dn	dn	dn	UP	UP
29	dn	dn	dn	UP	dn
30	dn	dn	dn	dn	UP
31	dn	dn	dn	dn	dn
BIT VALUE:	16	8	4	2	1



BATTERY INSTALLATION & REPLACEMENT

The 5706 is equipped with a dual battery harness that allows the use of two 9 volt batteries, which can double the time between battery replacement when compared to using a single 9 volt alkaline battery. The 5706 will operate with a single 9 volt battery, but the use of two 9 volt alkaline batteries is recommended for maximum battery life. Refer to the SPECIFICATIONS section for acceptable batteries for use in this product. *Note that using 2 lithium batteries DOES NOT double the life when compared to a single lithium battery.* The smoke detector's batteries should be changed within 30 days following the low battery beeps (about once every 50 seconds). If using two batteries, be sure to replace BOTH batteries with fresh ones when replacing weak batteries.


1. Remove the smoke detector from its mounting plate by twisting the detector counterclockwise. Remove the existing batteries.
2. Install fresh batteries in their correct positions. Be sure to observe correct polarity, and do not force the batteries. Follow the instructions in the next column for one or two battery installation.
3. Reinstall the smoke detector onto the mounting plate by turning it clockwise, and test its operation as described in the TEST section.
4. The LED indicator should flash about once every 12 seconds, indicating normal operation. If the batteries are not installed correctly, the smoke detector will not function. If the unit appears not to be sending a signal during any of the tests, check for correct battery installation.

If using a single battery: Remove the dual battery harness from the detector and snap a fresh 9 volt battery into the battery compartment, making sure it is fully seated.

If using Two Batteries: Snap the red wire contact of the battery harness onto the positive (+) terminal of a fresh 9 volt alkaline battery. Holding the contact on the battery, install the battery into the battery compartment as usual. Make sure the battery is fully seated.


Snap the second 9 volt alkaline battery onto the floating battery connector, and push the second battery into the space between the detector cover and the base. Dress both red and black wires through the 1/4" slot in the detector wall to assure that the wires are not pinched between the mounting bracket and the base of the detector when the detector is reinstalled to the mounting plate.

IMPORTANT: If using two batteries, do not mix battery types.




HOLDING TABS
LOCKING TABS ON MOUNTING
PLATE SLIDE BENEATH THESE TABS
(SMOKE DETECTOR IS LATCHED
ONTO MOUNTING PLATE BY
TURNING CLOCKWISE)

BOTTOM VIEW OF SMOKE DETECTOR (WITHOUT MOUNTING PLATE)



INSTALL THIS BATTERY FIRST



INSTALL THIS BATTERY SECOND

MOUNTING THE SMOKE DETECTOR



First, determine the best location for the smoke detector that provides strong wireless transmission paths AND proper smoke detector protection (see NFPA RECOMMENDATIONS ON SMOKE DETECTORS section). A good RF transmission path must be established from the proposed mounting location before permanently installing the smoke detector. To determine that there is good signal reception from the proposed location, perform the test in the TESTING THE SMOKE DETECTOR section.

1. Once a suitable location has been determined, install the mounting plate on the ceiling or (if local ordinances permit) on the wall. Use the two screws and anchors provided.
2. Latch the detector onto the mounting plate as follows: Align the detector against the plate by mating the small center post on the detector with the "dimple" at the center of the mounting plate. Turn the detector in a clockwise direction so that the holding tabs on the detector engage the locking tabs on the mounting plate.
3. Test the detector immediately after completing the installation and refer to the Control System's instructions for additional information concerning the use of wireless smoke detectors.

MOUNTING LOCATIONS

Detectors should be located as close to the center of the ceiling as possible. If this is not practical, detectors may be located on the ceiling up to four inches (10cm) from the ceiling-wall junction. Do not install them near forced air heating or air conditioning ducts (outlets or returns). For sloped, gabled or high peaked ceilings, detectors must be mounted between 4 and 6 (10 and 15cm) inches from the highest point in the ceiling.

Detectors may also be wall mounted if permitted by local and state codes. Check with your local Fire Department about code requirements. Wall mounted detectors should be located 4 to 6 inches (10 to 15 cm) from the ceiling. In mobile homes, battery-operated detectors are not installed by the manufacturer. Mount detectors ONLY on an interior wall.



NOTE: OTHER SIDE FACES CEILING OR WALL (THE WORDS "SHOULD GO" MUST FACE AWAY FROM MOUNTING SURFACE).

MOUNTING PLATE FOR SMOKE DETECTOR

NFPA RECOMMENDATIONS REGARDING DETECTOR INSTALLATION

For your information, the National Fire Protection Association's Standard 74, Section 204 reads as follows: "2-4.1.1; Smoke detectors shall be installed outside of each separate sleeping area and in the immediate vicinity of the bedrooms and on each additional story of the family living unit including basements and excluding crawl spaces and unfinished attics. The provisions of 2-4.1.1 represent the minimum number of detectors required by this standard. It is recommended that the householder consider the use of additional smoke or heat detectors for increased protection for those areas separated by a door from the areas protected by the required smoke detectors under 2-4.1.1 above. The recommended additional areas are: living room, dining room, bedrooms(s), kitchen, attic (finished or unfinished), furnace room, utility room, basement, integral or attached garage, and hallways not covered under 2-4.1.1 above. However, the use of additional detectors remains the option of the householder." This equipment should be installed in accordance with this standard (National Fire Protection Association, Batterymarch Park, Quincy, MA 02269). State and local codes and ordinances may conflict with the above standard. We suggest you contact your local fire authority for local requirements regarding smoke detectors.

RECOMMENDED LOCATIONS FOR SMOKE DETECTORS

To minimize the risk of fire causing injury, loss of life or loss of property, detectors should be located on every level of a residence – basements, first floor, second floor and attic if it is furnished – and in every separate sleeping area. More specifically, detectors should be located:

1. Between sleeping areas and potential sources of fire such as kitchen, garage, basement or utility room. In homes with only one sleeping area on one floor, a detector should be put in the hallway outside the bedrooms as shown below. In single floor homes with two separate sleeping areas, two detectors are required, one outside each bedroom area as shown below. In multi-level homes, detectors should be located in **bedroom areas and at every finished level of the home** as shown below. Basement level detector should be located in the **bottom** of basement stairwells. Second floor detectors should be located at the **top** of the first-to-second floor stairwell so long as no door or other obstruction blocks the path of smoke.
2. Inside every bedroom where a smoker sleeps or an electrical appliance is operated. This detector should be in **addition** to the hallway detectors as described above.
3. Inside all bedrooms where people sleep with the door closed. Smoke and poisonous combustion gases are significantly blocked by a closed door. This detector should be in **addition** to the hallway detectors described above.
4. At each end of a hallway serving the bedrooms if the hallway is in excess of 40 feet (12m) in length.




Diagram 5. TYPICAL SINGLE FLOOR INSTALLATION (ONE BEDROOM AREA)




Diagram 6. TYPICAL SINGLE FLOOR INSTALLATION (TWO BEDROOM AREAS)

WHERE NOT TO LOCATE DETECTORS

To avoid false alarms and/or improper operation, avoid installation of smoke detectors in the following areas:

- KITCHENS - smoke from cooking may cause a nuisance alarm. LOCATE DETECTORS AT LEAST 20 FEET (6m) FROM KITCHENS IF POSSIBLE.
- IN AIRSTREAMS PASSING BY KITCHENS - smoke from cooking may enter normal air movement paths between outlets and returns if these paths run by kitchens, causing a nuisance alarm. LOCATE DETECTORS AWAY FROM SUCH AIRSTREAMS IF POSSIBLE.
- BATHROOMS - excessive steam from a shower may cause a nuisance alarm. LOCATE DETECTORS AT LEAST 10 FEET (3m) FROM BATHROOMS IF POSSIBLE.
- NEAR FORCED AIR DUCTS used for heating or air conditioning - air movement may prevent smoke from reaching the detector.
- NEAR FLUORESCENT LIGHT FIXTURES - "noise" generated by these fixtures may cause a nuisance alarm.
- NEAR FURNACES OF ANY TYPE - air and dust movement and normal combustion products may cause a nuisance alarm.
- THE PEAK OF AN "A" FRAME TYPE OF CEILING - "Dead Air" at the top may prevent smoke from reaching the detector.
- GARAGES - products of combustion are present from running automobile engines and may cause a nuisance alarm.
- UNHEATED BUILDINGS - temperature limits are 40° - 100°F (5 - 38°C). The detector will not function properly in locations where the normal ambient temperature exceeds these limits.
- INSECT INFESTED AREAS - insects entering the sensing chamber may cause a nuisance alarm.

IF YOU EXPERIENCE NUISANCE ALARMS, CAREFULLY CHECK YOUR DETECTOR'S LOCATION FOR POSSIBLE CAUSES AS LISTED ABOVE. RELOCATE AND CLEAN YOUR DETECTOR IF NECESSARY. REMEMBER THAT THE MAJOR CAUSES OF NUISANCE ALARMS ARE DIRTY OR IMPROPERLY LOCATED DETECTORS




Diagram 7. TYPICAL MULTI-FLOOR INSTALLATION

- ⊗ Smoke Detectors for Minimum Protection
- ⊗ Smoke Detectors for Additional Protection
- △ Heat-Activated Detectors

TESTING THE SMOKE DETECTOR

The following procedure should be performed to determine strong radio path communication with the control, and again after installation is completed. THIS TEST SHOULD ALSO BE PERFORMED ON A REGULAR BASIS (AT LEAST WEEKLY) BY THE USER.

1. Activate the wireless system's test mode via the console.
2. Depress and hold the smoke detector's TEST button for at least 45 seconds. Within 15 seconds, the detector's horn will start to sound. The detector will begin to transmit alarm signals (about once every 12 seconds) within 20 seconds of the horn sounding.
3. The wireless system's console should emit at least 2 audible sounds each time an alarm transmission is received (about every 12 seconds while the TEST button is depressed), and will display the transmitting detector's ID number.
4. When satisfied that the console has received the test signal, release the TEST button. Within 10 seconds the detector's horn will stop. About 1 second later the console will emit two additional tones, and the ID number display will clear.
5. If the console does not respond as noted, check the battery connections and be sure batteries are fresh. If this is an initial installation, try moving the detector to another location that provides proper reception. Repeat the test.
6. Turn off the system's TEST mode via the console (security code + OFF).

SUMMARY OF FUNCTIONS

LED	HORN	STATUS
Flashes about 5 times a minute	Silent	Normal, functioning properly
Flashes about 5 times a minute	Beeps once every 50 seconds	Low battery or detector malfunction
Rapid flashing	On continuously	Alarm, detecting smoke

SPECIFICATIONS

- Power Source:** One or two 9 volt alkaline batteries. Use Ademco 464, Eveready 522, Duracell MN1604, or equivalent.
- Power/Alarm LED:** Standby = flashing once every 12 seconds
Alarm = rapid flashing
- Low Battery Signal:** One horn blip every 50 seconds.
- Size:** 6-5/8" inch (17cm) dia,
2-1/2" inch (6.4cm) high

TO THE INSTALLER

Regular maintenance and inspection (at least annually) by the installer and frequent testing by the user are vital to continuous satisfactory operation of any alarm system.

The installer should assume the responsibility of developing and offering a regular maintenance program to the user as well as acquainting the user with the proper operation and limitations of the alarm system and its component parts. Recommendations must be included for a specific program of frequent testing (at least weekly) to insure the system's proper operation at all times.

THE LIMITATIONS OF THIS SMOKE DETECTOR/TRANSMITTER

While this smoke detector/transmitter is a highly reliable device that is part of an advanced wireless security system, it does not offer guaranteed protection against fire. While smoke detectors have played a key role in reducing residential fire deaths in the United States, they may not activate or provide early warning for a variety of reasons in as many as 35% of all fires, according to data published by the Federal Emergency Management Agency. Some of the reasons smoke detectors used in alarm systems may not work are as follows:

- Smoke detectors will not work without power. Battery operated devices will not work without batteries, or if the batteries are not put in properly.
- Smoke detectors may have been improperly installed and positioned. Smoke detectors may not sense fires that start where smoke cannot reach the detectors, such as in chimneys, in walls, or roof, or on the other side of closed doors. Smoke detectors also may not sense a fire on another level of a residence or building. A second floor detector, for example may not sense a first floor fire or basement fire. In addition, smoke detectors have sensing limitations. No smoke detector can sense every kind of fire every time. In general, detectors may not always provide adequate warning about rapidly spreading fires caused by carelessness and safety hazards like smoking in bed, violent explosions, escaping gas, improper storage of flammable materials, children playing with matches, or arson. Depending on the nature of the fire and/or location of the smoke detectors, the detector, even if it operates as anticipated, may not provide sufficient warning to allow all occupants to escape in time to prevent injury or death.
- Alarm signal sent by the wireless transmitter in this device may be blocked or reflected by metal before they reach the alarm receiver. Even if the signal path has been recently checked during a weekly test, blockage can occur if a metal object is moved into the path.
- Alarm warning devices such as sirens, bells or horns may not alert people or wake up sleepers if they are located on the other side of closed or partly open doors. If warning devices are located on a different level of the residence from the bedrooms, then they are less likely to waken or alert people inside the bedrooms. Even persons who are awake may not hear the warning if the alarm is muffled by noise from a stereo, radio, air conditioner or other appliances, or by passing traffic. Finally, alarm warning devices, however loud, may not warn hearing impaired people or waken deep sleepers.
- This smoke detector/transmitter, like other electrical devices, is subject to component failure. Even though this device is designed to last as long as 20 years, the electronic components in it could fail at any time. We recommend that smoke detectors be replaced every 10 years as a precautionary measure against component failure.

The most common cause of an alarm system not functioning when a fire occurs is inadequate maintenance. The alarm system should be tested weekly to make sure all smoke detectors and their transmitters are working properly. Detectors must be repaired or replaced when they do not function properly.

Installing an alarm system may make the owner eligible for lower insurance rates, but an alarm system is not a substitute for insurance. Homeowners, property owners and renters should continue to act prudently in protecting themselves and continue to insure their lives and property.

We continue to develop new and improved protection devices. Users of alarm systems owe it to themselves and their loved ones to learn about these developments.

ADEMCO LIMITED WARRANTY

Alarm Device Manufacturing Company, a Division of Pittway Corporation, and its divisions, subsidiaries and affiliates ("Seller"), 165 Eileen Way, Syosset, New York 11791, warrants its products to be in conformance with its own plans and specifications and to be free from defects in materials and workmanship under normal use and service for 18 months from the date stamp control on the product or, for products not having an Ademco date stamp, for 12 months from date of original purchase unless the installation instructions or catalog sets forth a shorter period, in which case the shorter period shall apply. Seller's obligation shall be limited to repairing or replacing, at its option, free of charge for materials or labor, any product which is proved not in compliance with Seller's specifications or proves defective in materials or workmanship under normal use and service. Seller shall have no obligation under this Limited Warranty or otherwise if the product is altered or improperly repaired or serviced by anyone other than Ademco factory service. For warranty service, return product transportation prepaid, to Ademco Factory Service, 165 Eileen Way, Syosset, New York 11791.

THERE ARE NO WARRANTIES, EXPRESS OR IMPLIED, OF MERCHANTABILITY, OR FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE, WHICH EXTEND BEYOND THE DESCRIPTION ON THE FACE HEREOF. IN NO CASE SHALL SELLER BE LIABLE TO ANYONE FOR ANY CONSEQUENTIAL OR INCIDENTAL DAMAGES FOR BREACH OF THIS OR ANY OTHER WARRANTY, EXPRESS OR IMPLIED, OR UPON ANY OTHER BASIS OF LIABILITY WHATSOEVER, EVEN IF THE LOSS OR DAMAGE IS CAUSED BY THE SELLER'S OWN NEGLIGENCE OR FAULT.

Seller does not represent that the products it sells may not be compromised or circumvented; that the products will prevent any personal injury or property loss by burglary, robbery, fire or otherwise; or that the products will in all cases provide adequate warning or protection. Customer understands that a properly installed and maintained alarm may only reduce the risk of a burglary, robbery, fire or other events occurring without providing an alarm, but it is not insurance or a guarantee that such will not occur or that there will be no personal injury or property loss as a result. CONSEQUENTLY, SELLER SHALL HAVE NO LIABILITY FOR ANY PERSONAL INJURY, PROPERTY DAMAGE OR OTHER LOSS BASED ON A CLAIM THE PRODUCT FAILED TO GIVE WARNING. HOWEVER, IF SELLER IS HELD LIABLE, WHETHER DIRECTLY OR INDIRECTLY, FOR ANY LOSS OR DAMAGE ARISING UNDER THIS LIMITED WARRANTY OR OTHERWISE, REGARDLESS OF CAUSE OR ORIGIN, SELLER'S MAXIMUM LIABILITY SHALL NOT IN ANY CASE EXCEED THE PURCHASE PRICE OF THE PRODUCT, WHICH SHALL BE THE COMPLETE AND EXCLUSIVE REMEDY AGAINST SELLER. This warranty replaces any previous warranties and is the only warranty made by Seller on this product. No increase or alteration, written or verbal, of the obligations of this Limited Warranty is authorized.



ALARM DEVICE MANUFACTURING CO.
A DIVISION OF PITTMAN CORPORATION
165 Eileen Way, Syosset, New York 11791

N4469V2 12/91

Copyright © 1988 PITTMAN CORPORATION